



Drinking Water Quality and Compliance Village of Bethune - 2016 Annual Notice to Consumers

Introduction

Saskatchewan Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Village of Bethune water quality and sample submission compliance record for the January 1 – December 31, 2016 time period. This report was completed on January 26, 2017. Readers should refer to Environment's [Municipal Drinking Water Quality Monitoring Guidelines](#), November 2002, EPB 202 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: www.hd-sc.gc.ca/ewh-semt/pubs/water-cau/index

Water Quality Standards Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL	52	52	0

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples				
Parameter	Minimum	Total Chlorine Residual Range	# Tests Required	# Adequate Chlorine (%)
Chlorine	0.1 mg/L free OR			
Residual	0.5 mg/L total	0.63-1.48/l	52	100%
		0.05-1.33/l	52	

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.34-1.80mg/l	365	0

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	no standard	0.08-0.46 NTU	0	4.8 ntu		365

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

Parameter	Limit MAC(mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit
Arsenic	25		1.3 ug/l	
Barium	1		81.4 ug/l	
Boron	5		0.1 mg/l	
Cadmium	0.005		<0.56 ug/l	
Chromium	0.05		<0.11 ug/l	
Fluoride (avg*)	1.5 mg/l		0.1 mg/l	
Lead	0.01		0.6 ug/l	
Nitrate (avg.*)	45		<0.20mg/l_	
Selenium	0.01		<0.96 ug/l	
Uranium	20 ug/l		1.7 ug/l	

* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.

Chemical – Trihalomethanes (THMs)

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1-	<100 ug/l	4	4

Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs since sampling/analysis will not likely have been performed.

General Chemical

Parameter	Aesthetic Objectives* (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	217 mg/l		1
Bicarbonate	No Objective	265 mg/l		1
Calcium	No Objective	74 mg/l		1
Carbonate	No Objective	<0.0 mg/l		1
Chloride	250	52 mg/l		1
Conductivity	No Objective	1160 Us/cm		1
Hardness	800	362 mg/l		1
Magnesium	200	43 mg/l		1
PH	No Objective	7.5 ph units		1
Sodium	300	128 mg/l		1
Sulphate	500	326.3 mg/l		1
Total dissolved Solids	1500	902 mg/l		1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The last sets of quarterly samples for General Chemical analysis were required on 2015, and were submitted on April 6, 2015. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category .Sample results indicated that the provincial drinking water quality standards were not exceeded.

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Village of Bethune
Box 209, Bethune, Sask. S0G 0H0
(306) 638-3188
villageofbethune@sasktel.net

January 2017